

Event Count	DA/RT	Unit Name	Start Date	End Date	Duration (Hours)	Reduction (AVG MW)	Description
1	Real Time	Hope Creek 1	2/7/2014 3:00	2/7/2014 16:32	13.53	91	<OMCI> 5015 Line Outage
2	Real Time	Hope Creek 1	11/21/2014 3:45	11/21/2014 22:19	18.57	31.4	<OMCI> 5015 Line Outage
3	Real Time to start, then Day Ahead	Hope Creek 1	11/3/2015 4:00	11/11/2015 17:54	205.9	192.4	<OMCI> 5015 Line Outage
4	Day Ahead	Hope Creek 1	2/4/2016 4:00	2/4/2016 23:37	19.62	130	<OMCI> 5038 Line Outage
5	Day Ahead	Hope Creek 1	11/13/2016 5:07	11/13/2016 15:45	10.63	821	<OMCI> 5015 Line Outage
6	Real Time	Salem 1	2/7/2014 2:00	2/7/2014 3:26	1.43	89	<OMCI> Commenced Turbine load reduction at 10%/hour to 65% for 5015 500KV line outage on day
	Real Time	Salem 1	2/7/2014 3:26	2/7/2014 4:14	0.8	233	<OMCI> Commenced Turbine load reduction at 10%/hour to 65% for 5015 500KV line outage on day
	Real Time	Salem 1	2/7/2014 4:14	2/7/2014 4:52	0.63	324	<OMCI> Commenced Turbine load reduction at 10%/hour to 65% for 5015 500KV line outage on day
	Real Time	Salem 1	2/7/2014 4:52	2/7/2014 14:30	9.63	397	<OMCI> Commenced Turbine load reduction at 10%/hour to 65% for 5015 500KV line outage on day
	Real Time	Salem 1	2/7/2014 14:30	2/7/2014 15:15	0.75	267	<OMCI> Commenced Turbine load reduction at 10%/hour to 65% for 5015 500KV line outage on day
	Real Time	Salem 1	2/7/2014 15:15	2/7/2014 17:00	1.75	171	<OMCI> Commenced Turbine load reduction at 10%/hour to 65% for 5015 500KV line outage on day
7	Real Time	Salem 1	5/18/2015 7:32	5/19/2015 1:45	18.22	12.2	<OMCI> 5021 Line Outage
	Real Time	Salem 1	5/19/2015 1:45	5/19/2015 15:58	14.22	8.2	<OMCI> 5021 Line Outage
	Real Time	Salem 1	5/19/2015 15:58	5/20/2015 2:05	10.12	15.2	<OMCI> 5021 Line Outage
	Real Time	Salem 1	5/20/2015 2:05	5/20/2015 4:50	2.75	10.2	<OMCI> 5021 Line Outage
	Real Time	Salem 1	5/20/2015 4:50	5/20/2015 8:15	3.42	15.2	<OMCI> 5021 Line Outage
8	Real Time to start, then Day Ahead	Salem 1	11/3/2015 15:15	11/11/2015 16:39	193.4	206.8	<OMCI> 5015 Line Outage
9	Real Time	Salem 1	2/4/2016 11:50	2/5/2016 3:18	15.47	13.2	<OMCI> (A) Gen Load Reduction per PJMRequest (5038 line outage)
10	Real Time	Salem 2	10/14/2013 21:30	10/16/2013 1:53	28.38	119	<OMCI> Bottled Capacity
11	Real Time	Salem 2	11/21/2014 3:35	11/21/2014 20:25	16.83	82.7	<OMCI> 5015 Line Outage
12	Day Ahead	Salem 2	2/4/2016 6:30	2/4/2016 11:22	4.87	254.8	<OMCI> Downpower to support 5038 LineOutage